

EBC Update



TOWN OF WESTFORD
BUILDING DEPARTMENT

TOWN HALL
55 Main Street
WESTFORD, MA 01886
(978) 692-5527 FAX (978) 399-2558

August 9, 2007

Steve Ledoux
Town Manager
Town of Westford
55 Main Street
Westford, MA 01886

Steve,

I performed an electrical inspection at East Boston Camps on August 8, 2007 with George Fletcher and Chris Tremonte, Director of East Boston Camps.

I accessed each building of the Girls and Boys camps. All the interior of the buildings I inspected were free of any faulty wiring, switches, receptacles, and lighting fixtures were equipped with covers. Throughout the property there telephone and communication wiring that is no longer in use. The electrical service drops in many of the cabins (boys & girls) did not meet the minimum 10 foot clearance. There were also abandoned wires in the boy's beach area.

Overall, I felt the cabins were in good shape and I recommend the following work be performed to meet the remaining 2007 camping season:

- 1) Raise service cable connections upward to maximize height
- 2) Remove any low voltage wiring that is not being used
- 3) Remove the abandoned wiring in the boys beach area
- 4) Cover meter sockets to prevent anyone from coming in contact

George Fletcher stated they have an electrical contractor and assured me these issues will be completed by Friday August 10, 2007. I will be performing a post electrical inspection after all work is completed.

Regards,

Dennis P. Kane, Jr.
Wire Inspector
Town of Westford

CC: Matthew Hakala

RECEIVED

AUG 09 2007

OFFICE, OF TOWN MANAGER